

# Engineering Specifications



**Project:**

**Location:**

**Index:**

## ► Domestic Hot Water Storage Tanks

Vitocell 300-H, EHA-119 Stainless Steel DHW Tank (Qty. of 1)

## ► System Accessories

### DHW Tank Specifications: Vitocell-H 300, EHA-119

#### 1.0 Performance Criteria

The DHW tank shall have a storage capacity of no less than 119 USG (450 L).

The tank shall be suitable for domestic hot water production in combination with a hot water heating system.

The tank shall be designed for use on heating systems with the following operating conditions:

- Tank operating conditions: maximum operating pressure 150 psig at 210°F (99°C)
- Heat exchanger coil operating conditions: maximum hot water operating pressure 220 psig at 392°F (200°C)

#### 2.0 Construction

Each hot water storage tank shall have an integrated stainless steel, smooth-surfaced, non-finned, conically shaped, rectangular-coiled heat exchanger. Both the tank and heat exchanger shall be made of fully hygienic, high-alloy stainless steel.

The 1¼" (32mm) diameter internal tubular heat exchanger shall be designed with a large surface coil area in the lower portion of the tank to allow rapid and uniform heating of the water in the tank with a low pressure drop through the heat exchanger coil. The coil shall be designed so as to be both self-draining and self-venting, be non-finned with space between passes, and be tapered to allow full output from all passes of the coil.

The tank shall be equipped with a stainless steel sensor well.

Tank enclosure panels shall encase the tank with a minimum of 2¼" (58mm) foamed-in-place PUR foam (HCFC-free). The enclosure panels of these tanks shall be removable to allow transportation through standard doorways. The tank shall be equipped with NPT threaded connections, for attachment of each threaded nipple to boiler water or domestic water piping, without the use of adaptors.

Each tank shall have a front-mounted inspection / clean-out port, and be equipped with a thermometer registering tank water temperature.

The tank construction shall support the weight of intended boiler to be placed on top. Four levelling feet shall be provided on the tank base to allow for easy adjustment.

#### 3.0 Certifications

The tank shall have the following approvals and listings, or be in compliance with:

CSA, CRN (BC, PQ), NY City approval, MA State approval

#### 4.0 Installation

Horizontal stainless steel tanks shall be stackable into tank batteries, up to 3 units high.

All water connections shall be accessible once the tank is installed, for ease of service.

A 3/4" pressure and temperature relief valve shall be factory supplied and field installed to meet local Canadian or U.S. codes (CSA ratings shall be followed). The maximum pressure relief setting shall be 150 psi at 210°F (99°C).

Technical information subject to change without notice. Viessmann reserves the right to correct errors in graphics, files, text and technical data. Some product may not be exactly as illustrated. Viessmann will not be held liable, financially or otherwise, for product changes, discontinuations or delays.

© 2025 Carrier. All rights reserved.

Carrier is a trademark of the Carrier Corporation, and is registered with the U.S. Patent and Trademark Office. Viessmann is a trademark of Viessmann Group GmbH & Co. KG, and is registered with the U.S. Patent and Trademark Office. For further copyright, trademark and disclaimer information, please visit: [www.viessmann.ca/en/copyright.html](http://www.viessmann.ca/en/copyright.html)